# **Tubular Industrial Process**




### **Bulb & Capillary Thermostats**


# Thermostat Wiring Diagrams

### Thermostat Style D (Single Pole-Single Throw)

Typical circuit when voltage and/or line current does not exceed thermostat ratings




1Ø or 3Ø circuit if line voltage and/or current exceeds thermostat rating




#### Thermostat Style D (Single Pole-Double Throw)

Typical circuit when voltage and/or line current does not exceed thermostat ratings



1Ø or 3Ø circuit if line voltage and/or current exceeds thermostat rating



# Stock Thermostat Enclosures

# Thermostat Installation Warnings & Recommendations

- 1. Do not use the thermostat as a power switch. Use some other means of disconnecting power to the heater for servicing.
- A thermostat is not a fail-safe device. Use an approved high temperature limit control and/or pressure limit control for safe operation.
- Avoid kinking or bending the capillary tube too sharply as this will alter the calibration and/or render the thermostat inoperable.
- 4. Excess capillary tube should be coiled neatly in junction box.
- The capillary tube must never touch the thermostat contacts as this will create an electrical short capable of harming personnel and/or equipment.



# **NEMA 1 Enclosure**For Single-Pole Thermostats

Size: 4-1/4"H × 3"W × 2"D with 3/4" trade size knockout **Part Number: HSGR-1003** 





**NEMA 1 Enclosure** 

#### For Double-Pole Thermostats

Size: 6-1/2"H × 3-3/4"W × 2-1/2"D with 1/2" trade size knockout Used with Thermostat kits TSTR-1008 and TSTR-1009 shown on page 11-7.

Part Number: HSGR-1004